



SUMMARY TEST REPORT

FOR: Andersen Corporation
 100 Fourth Avenue North
 Bayport, MN 55003

Report Number: D2587.03-201-44
 Test End Date: 12/11/2013
 Report Date: 02/28/2014
 Test Record Retention End Date: 02/28/2018

SERIES TESTED:

A-Series Frenchwood Gliding Patio Door with Stormwatch Protection/
 FWGD1110611ASA IG IR

MODEL TESTED

Sliding Glass Door

NAFS-08/-11

Class LC PG50 Size Tested 141.0 x 82.4 in.
 DP+50/-70*

Test

Operating Ease
 Resistance to Air Infiltration
 Resistance to Water Penetration
 Resistance to Structural Loading
 Forced Entry Resistance

Results Summary

Pass, 27 N (6 lbf) max.
 0.09 cfm/ft² (ASTM E283)
 Pass at DP50 (ASTM E547)
 Pass at DP50 (ASTM E330)
 Pass (ASTM F 842)

CAN/CGSB-82.1-M89, Evaluation to the prescriptive requirements were not performed

Test

Operating Ease
 Air Tightness
 Water Tightness
 Wind Load Resistance
 Blow-Out

Rating

Pass, 27 N (6 lbf) max.
 A3
 B3
 C3
 C3

Test

Impact
 Pressure Cycling

Results Summary

No rips, tears or penetrations
 DP+50/-70

REFERENCE:

See ATI Report No. D2587.01-201-44, D2587.02-201-44 and D2587.04-201-44 for complete test results. Reference Architectural Testing, Inc. Report No. D2589.01-201-44 dated 01/28/14 for complete *Gateway* test specimen description and test results.

A copy of this report will be retained by ATI for a period of four years. This report is the exclusive property of the client named herein and is applicable to the sample tested. Results obtained are tested values and do not constitute an opinion or endorsement by this laboratory.

ARCHITECTURAL TESTING, INC

ARCHITECTURAL TESTING, INC

Tony D. Gavin
 Technician

Daniel A. Johnson
 Director - Regional Operations

849 Western Avenue North
 St. Paul, MN 55117
 Phone: 651-636-3835
 Fax: 717-764-4129
 www.archtest.com